

Certificate

Registration No.: PV 50213195

Page 1

Report No.: 15043460.001

License Holder:

JieYang Zhongcheng Group Co., Ltd.
Center Road, Economic Development
Experimental Zone Of Jieyang City,
Guangdong Province 522013,
P.R. China

Manufacturing Plant:

JieYang Zhongcheng Group Co., Ltd.
Center Road, Economic Development
Experimental Zone Of Jieyang City,
Guangdong Province 522013,
P.R. China

Product:

PV Module

Type:

With 6" mono cells:

ZCM6-72P-xxxW (xxx= 260-315, in steps of 5, 72 cells)

ZCM6-60P-xxxW (xxx= 215-260, in steps of 5, 60 cells)

ZCM6-54P-xxxW (xxx= 195-235, in steps of 5, 54 cells)

With 6" poly cells:

ZCP6-72P-xxxW (xxx= 250-300, in steps of 5, 72 cells)

ZCP6-60P-xxxW (xxx= 210-250, in steps of 5, 72 cells)

ZCP6-54P-xxxW (xxx= 190-225, in steps of 5, 72 cells)

With 5" mono cells:

ZCM5-72P-xxxW (xxx= 170-200, in steps of 5, 72 cells)

ZCM5-36P-xxW (xx= 85-95, in steps of 5, 36 cells)

Basis:

- IEC 61730-1:2004
IEC 61730-2:2004
EN 61730-1:2007
EN 61730-2:2007
"Photovoltaic (PV) module safety qualification"

- Factory Inspection**
To document the consistent quality of
the product factory inspections are
performed periodically.



- Qualified, IEC 61215
- Safety tested,
IEC 61730
- Periodic inspection

Remarks:

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to 1000 VDC.
- The fire test (IEC 61730-2 / MST 23) was not performed.
- The details of the factory inspection are documented in report no. 16033201.001.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 20 September 2016.

Shanghai, 21 September 2011



TÜV Rheinland LGA Products GmbH, Tillystrasse 2, D-90431 Nürnberg
Contact: + (+49) 221 606-1371 email: cert-validity@de.tuv.com